

AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT				1. Contract Number		Page of Pages	
						1	3
2. Amendment/Modification Number DCAM-2007-B-0055-002		3. Effective Date March 19, 2007		4. Requisition/Purchase Request No.		5. Solicitation Caption Construction of an "Open Office" Style Work Environment at the John A. Wilson Building	
6. Issued by: Office of Contracting and Procurement Construction, Design and Building Renovation 441 4 th Street, NW, Suite 700S Washington, DC 20001				Code LRT		7. Administered by (If other than line 6) Office of Contracting and Procurement Construction, Design and Building Renovation 441 4 th Street, NW, Suite 700S Washington, DC 20001	
8. Name and Address of Contractor (No. street, city, county, state and zip code)				9A. Amendment of Solicitation No. DCAM-2007-B-0055			
				9B. Dated (See Item 11) March 6, 2007			
				10A. Modification of Contract/Order No.			
				10B. Dated (See Item 13)			
Code	DUNS:	TIN	FEIN:				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended. <input type="checkbox"/> is not extended. Offeror's must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>2</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) BY separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. Accounting and Appropriation Data (If Required) <i>To be cited on individual orders issued on behalf of participating agencies</i>							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14							
X	A. This change order is issued pursuant to (Specify Authority): 27 DCMR, Chapter 36, Section 3603 The changes set forth in Item 14 are made in the contract/order no. in item 10A.						
	B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation data etc.) set forth in item 14, pursuant to the authority of						
	C. This supplemental agreement is entered into pursuant to authority of:						
	D. Other (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not <input checked="" type="checkbox"/> is required to sign this document and return 2 copies to the issuing office.							
14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible) Pursuant to Article 3, Changes Clause of the General Provisions (Construction Contract), Government of the District of Columbia Standard Contract Provisions For Use With Specifications for District of Columbia Construction Projects 1973, the subject solicitation is hereby amended as follows: 1. The opening date for receipt of bids is hereby changed from March 20, 2007, by 2:00 P.M. local time to March 22, 2007, by 2:00 P.M. local time. 2. In accordance with all drawings numbered A.02, 2.a. of the General Requirement, Contractors are to return all 3 sets of drawings on the date of bid opening. Except as provided herein, all terms and conditions of the document is referenced in Item 9A or 10A remain unchanged and in full force and effect.							
15A. Name and Title of Signer (Type or print)				16A. Name of Contracting Officer Diane Wooden			
15B. Name of Contractor		15C. Date Signed		16B. District of Columbia		16C. Date Signed 3/19/07	
(Signature of person authorized to sign)				(Signature of Contracting Officer)			

Continuation)

Contract Number	Amendment/Modification No.	Effective Date	Page of Pages
DCAM-2007-B-0055	DCAM-2007-B-0055-002	March 19, 2007	2 of 3

14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible).

3. Listed below is the response to questions asked at the time of the site visit held on February 13, 2007, and as submitted to the Office of Contracting and Procurement in writing as Request for Information (RFI) 001 dated March 14, 2007 and RFI 002 dated March 15, 2007.

Clarification to Question 1:

1. Pertinent Architectural Keynotes: There appears to be a discrepancy as to which Architectural Keynotes Listed are applicable to this solicitation. For example during yesterdays' Pre-proposal Conference, the Government stated there was an unwritten duplication of Architectural Keynotes between two separate and distinct contracts. That the Keynotes relative to a "Demolition Contract" were inadvertently carried over to the "Construction Contract " and that items of work such as carpet replacement, repair, cleaning and restoration would be accomplished by others prior to our commencement of construction activities.

Since Keynotes AK-03, AK-04, AK-05, AK-06, AK-08 and Ak-09 are all obvious duplications. Is the prospective Construction Contractor assume ...that these notes pertain to a separate and distinct demolition contract...and that all work relative to these notes will be completed, prior to the commencement of this project?

Response to Clarification Question 1:

1. Where duplications exist in the key notes between two contracts, the Construction Contractor SHALL NOT assume that ALL work relative to the notes will be completed prior to the commencement of the project. Although, it specifically relates to the carpet tiles, complete repositioning of the entire area will be necessary as this work is being done by the existing contractor. However, the key notes are called for the contractor to verify the amount of minor repositioning that may be needed.

It is important to note that dust and debris resulting from work performed by the construction contractor and All vendors during the duration of this project may make it necessary to abide by all applicable and "duplicate" key notes, specifically *AK05 EXISTING CARPET TO REMAIN-CLEAN REQUIRED TO RESTORE TO "LIKE NEW" CONDITION.*

Continuation)

Contract Number	Amendment/Modification No.	Effective Date	Page of Pages
DCAM-2007-B-0055	DCAM-2007-B-0055-002	March 19, 2007	3 of 3

14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible).

Clarification to Question 2:

2. Product Data for the Existing Suspended Acoustical Ceiling System:

Pursuant to Architectural Keynote AK-08 the contactor is to *repair or replace existing ceiling grid and tiles as required to restore to "like new condition and provide a continuous ceiling.*

In order to responsibly price the cost of this work and to ensure product availability with in the proposed performance period, the contractor will need to know the specifics of the existing ceiling system such as: manufacturer, system type, model, style and part numbers.

This information is essential because of the numerous manufacturers, quality grades, characteristics and systems on the market today.

Response to Clarification Question 2:

2. Attached is the appropriate page from the Architectural Base Building Specifications Binder for the John A. Wilson Building as it relates to the ceiling suspension system, acceptable manufactures, and ceiling panels.

NOTE: The Project Manager and Technical Representative visual inspection of the samples in stock and grid installed...manufacturer Chicago Metallic Corp appears to be the system in place. In addition, the following specifications that appears on the box of tiles is in stock, USG 76907 Fineline Bevel 3/4" 2' x2'.